



Maintenance

The Tubosider product itself requires no maintenance. Tubosider products have a minimum design life of 60 years, the design life can be extended to suit individual project requirements.

The Tubosider product has been specifically design with manhole access points with ladders, to gain entry to the system and it is the system that will require inspection.

The frequency of inspection will vary from project to project. We would recommend that the first inspection is carried out 12 months after the product has been installed. Over a period of time all attenuation tanks will have a very gradual build up of silt, the level of build up needs to be monitored and from this information the frequency of inspection can be decide.

A gully sucker can be used to remove any silt build up or this can be done manually.

The tank inspection needs to be carried out by someone who has successfully completed a confined space training course.